

**STATE OF VERMONT  
PUBLIC UTILITY COMMISSION**

Case No. 17-3550-INV

|   |  |
|---|--|
| Investigation pursuant to 30 V.S.A. §§ 30 and 209 regarding the alleged failure of Vermont Gas Systems, Inc. to comply with the certificate of public good in Docket 7970 by burying the pipeline at less than required depth in New Haven, Vermont |  |
|---|--|

Case No. 18-0395-PET

|  |  |
|--|--|
| Notice of Probable Violations of Vermont Gas Systems, Inc. for certain aspects of the construction of the Addison natural gas pipeline |  |
|--|--|

**REBUTTAL TESTIMONY OF  
CARLOS J. CHAVES  
ON BEHALF OF VERMONT GAS SYSTEMS, INC.**

November 1, 2021

**Summary of Testimony**

Mr. Chaves responds to Mr. Liebert's retracted September 10, 2021 testimony and Mr. Liebert's October 4, 2021 testimony. Mr. Chaves explains how the HS20+15% loading standard is evaluated, including the various kinds of stress that are assessed in the surface loading calculation. Mr. Chaves also explains how Mr. Liebert misapplied the ASME B31.8 standard, leading to the faulty conclusion that the total allowable stress is 50% of the Specified Minimum Yield Strength rather than 90% of the Specified Minimum Yield Strength as set forth in Section 833 of B31.8.

**EXHIBIT LIST**

- Exhibit VGS-CC-3 – 49 C.F.R. § 192.111
- Exhibit VGS-CC-4 – 49 C.F.R. § 192.105
- Exhibit VGS-CC-5 – Development of a Pipeline Surface Loading Screening Process
- Exhibit VGS-CC-6 – Mr. Liebert's Loading Calculations from October 4, 2021
- Exhibit VGS-CC-7 – CEPA Surface Loading Calculator User Manual

**REBUTTAL TESTIMONY OF  
CARLOS J. CHAVES  
ON BEHALF OF VERMONT GAS SYSTEMS, INC.**

1 **Q1. What is your name, occupation, and business address?**

2 **A1.** My name is Carlos J. Chaves. I am a Principal Project Manager with Mott MacDonald, a  
3 professional engineering consulting firm. The Mott MacDonald office that I am based out of is  
4 located at 134 Capital Drive – Suite D, West Springfield, Massachusetts 01089.

5 **Q2. Have you provided testimony in this case previously?**

6 **A2.** Yes. I provided direct testimony dated September 10, 2021.

7 **Q3. What is the purpose of your rebuttal testimony?**

8 **A3.** I respond to Mr. Gregory Liebert's testimony, which claims that Mott MacDonald's  
9 loading calculations were not correct. At first, Mr. Liebert claimed there were a number of  
10 problems with our loading calculations, including problems with input values for (1) axle-  
11 weight, (2) bedding angle, and (3) soil strength. On October 4, 2021, Mr. Liebert submitted  
12 revised testimony, removing his testimony about these issues. Accordingly, it is my  
13 understanding that Mr. Liebert no longer disputes whether we have used the appropriate inputs  
14 for (1) axle-weight, (2) bedding angle, and (3) soil strength. As a result, I do not provide any  
15 rebuttal to his original testimony on those issues, however, I do provide some relevant  
16 background about those issues where I think it may be helpful.


17 My testimony is focused on Mr. Liebert's sole remaining criticism of our loading  
18 calculations, which alleges that Mott MacDonald's calculations do not apply the appropriate

1 “Design Factor.” In particular, Mr. Liebert’s testimony about the Class 3 Design Factor  
2 demonstrates a misunderstanding about how the Class 3 Design Factor under 49 C.F.R. §§  
3 192.111, 192.105, and ASME B31.8 § 841 applies to surface loading calculations. Accordingly,  
4 my testimony first provides an explanation of the different kinds of stresses that are considered  
5 when calculating the impact of a HS20+15% loading standard. Second, I explain how the Design  
6 Factor requirements of 49 C.F.R. §§ 192.111, 192.105 and ASME B31.8 § 841 apply to these  
7 calculations. Finally, I explain how the overall pass/fail threshold is established for the loading  
8 standard based on applicable safety factors relating to longitudinal, circumferential, and  
9 combined allowable stress on a pipeline.

10 **Q4. What are the different kinds of stress and stress limitations that are considered**  
11 **when performing a HS20+15% surface loading calculation?**

12 **A4.** There are several kinds of stresses that are relevant to calculating whether a pipeline  
13 meets a HS20+15% loading standard. First, an overview of what it means to calculate surface  
14 loading under a HS20+15% loading standard may be helpful context. HS-20 loading is a design  
15 criteria of the American Association of State Highway Transportation Officials (“AASHTO”)  
16 that assumes a 16,000-pound single wheel load and therefore a 32,000-pound axle load. The  
17 +15% represents an additional safety factor above the HS20 load, which is calculated by adding  
18 15% to the applicable HS20 load, resulting in a 18,400-pound single wheel load and therefore a  
19 36,800-pound axle load. Accordingly, the assessment of a HS20+15% loading standard involves  
20 evaluating whether the pipeline can withstand the stresses imposed by a vehicle with this weight.

1           Generally, there are two kinds of stresses imposed on the pipeline, (1) hoop stress, which  
2 is also referred to as circumferential stress, and (2) longitudinal stress, which is also referred to  
3 as axial stress. Hoop stress is the stress imposed on the circumference of the pipeline. This  
4 includes the stress imposed by the pressure of the natural gas inside the pipeline and the bending  
5 stresses due to the surface and earth loads. An example of hoop stress would be the stress  
6 imposed on a straw if you pinched it with two fingers. Longitudinal stress refers to the stress  
7 imposed along the length of the pipeline. This includes the stresses from internal pressure,  
8 surface and earth loads due to the Poisson Effect, axial deflection, and temperature differential.  
9 If you held a straw on both ends, a component of longitudinal stress would be the stress  
10 associated with bending the straw along its length. The following diagram illustrates these  
11 different kinds of stress.<sup>1</sup>



12 To calculate and evaluate the overall stresses acting on a pipeline, we account for the following  
13 forces:

- 14           1) Internal gas pressure inside the pipe;
- 15           2) Weight of the soil above the pipe;
- 16           3) Surface or live load acting on the pipe; and

---

<sup>1</sup> [http://monghaihen.blogspot.com/2016/06/blog-post\\_14.html](http://monghaihen.blogspot.com/2016/06/blog-post_14.html).

1           4) Temperature differential.

2           To evaluate whether a pipeline meets a HS20+15% loading standard, the stress resulting  
3 from the applied surface load of HS20+15% is determined and compared against the allowable  
4 stress levels in ASME B31.8. In other words, we are calculating the circumferential and  
5 longitudinal stress acting on the pipeline resulting from a surface load of an 18,400-pound single  
6 wheel load. The stresses imposed by this surface load are then combined with the stresses present  
7 under normal operating conditions to determine the total circumferential, total longitudinal, and  
8 total combined equivalent stress experienced by the pipeline. Finally, we look at whether these  
9 calculated stress values are lower than the maximum permitted values in ASME B31.8 Section  
10 833. The maximum permitted values according to ASME B31.8 are detailed below:

- 11       • Total Longitudinal Stress: ASME B31.8 Section 833.3 (b) “The maximum permitted  
12 value of  $S_L$  is  $0.9ST$ ” or 90% of the specified minimum yield strength (“SMYS”).
- 13       • Total Circumferential Stress: ASME B31.8 Section 833.9 (b) “The maximum allowable  
14 sum of circumferential stress due to internal pressure and circumferential through-wall  
15 bending stress caused by a surface vehicle loads or other local loads is  $0.9ST$ ” or 90% of  
16 SMYS.
- 17       • Total Combined Biaxial Stress: ASME B31.8 Section 833.4 “The maximum permitted  
18 value for the combined biaxial stress is  $kST$ ” where  $k$  is defined as 0.90 for “loads of long  
19 duration” and 1.0 for “loads of short duration” or 90% of SMYS for long duration loads  
20 or 100% of SMYS for short duration loads.

1 **Q5. How is the internal hoop stress calculated?**

2 **A5.** The internal hoop stress is one of the stress components that is present under normal  
3 operating conditions. It is the stress imposed by the pressure of the natural gas inside the pipe,  
4 expressed in pounds per square inch (“psi”). The internal hoop stress is calculated according to  
5 Barlow’s Formula, which can be expressed as  $S_H = PD/2t$ , where  $S_H$  equals the internal hoop  
6 stress. The steel pipe input values for this internal hoop stress formula, specifically the nominal  
7 wall thickness (“t”), diameter (“D”) and specified minimum yield strength (“S”) are first  
8 computed by utilizing the “Design formula for steel pipe” in 49 C.F.R. § 192.105 or the “Steel  
9 Pipe Design Formula” from ASME B31.8 841.1.1, which are both expressed as  $P = (2 St/D) \times F$   
10  $\times E \times T$ .<sup>2</sup> Based on this Design formula and the operator’s preferred Design Pressure, the  
11 required minimum steel pipe design values are computed by applying the design factors for a  
12 Class 3 location ( $F = 0.5$ ), the longitudinal joint factor ( $E = 1.0$ ) and the temperature derating  
13 factor ( $T = 1.0$ ) in accordance with the design formula. This calculation informs the operator of  
14 the minimum required steel pipe parameters (diameter, wall thickness, etc.) that are required for  
15 the Design Pressure. For the ANGP pipeline, a nominal wall thickness of 0.312”, a diameter of  
16 12.75”, and a specified minimum yield strength (SMYS) of 65,000 psi were selected.

---

2

|   |   |  |
|---|---|--|
| P | = | Design pressure in pounds per square inch (kPa) gauge.   |
| S | = | Yield strength in pounds per square inch (kPa) determined in accordance with <a href="#">§ 192.107</a> . |
| D | = | Nominal outside diameter of the pipe in inches (millimeters).  |
| t | = | Nominal wall thickness of the pipe in inches (millimeters).  |
| F | = | Design factor determined in accordance with <a href="#">§ 192.111</a> .                                  |
| E | = | Longitudinal joint factor determined in accordance with <a href="#">§ 192.113</a> .                      |
| T | = | Temperature derating factor determined in accordance with <a href="#">§ 192.115</a> .                    |

1 VGS has established a Maximum Operating Pressure (“MOP”) of 1440 for ANGP,  
2 therefore; according to Barlow’s Formula, when the ANGP operates at its MOP of 1440, the  
3 pressure of the gas produces an internal hoop stress ( $S_H$ ) on the pipe of 29,423 psi.

$$S_H = PD/2t$$

$$S_H = 1440 \times 12.75'' / 2 \times 0.312'' = 29,423$$

4  
5 Accordingly, in all of Mott MacDonald’s loading calculations (as well as the calculations  
6 performed by Mr. Liebert), the internal hoop stress component of the calculations is 29,423 psi.  
7 This value is the same in all calculations because it is based on the same inputs for specified wall  
8 thickness, diameter, SMYS, and operating pressure of the ANGP. The internal hoop stress does  
9 not change with pipeline depth, surface load, or other factors.  
10

11 **Q6. What is the maximum allowable internal hoop stress on the ANGP?**

12 **A6.** The Design Pressure and the resulting internal hoop stress produced by the Design  
13 Pressure is regulated under 49 C.F.R. § 192.105.<sup>3</sup> Section 192.105 establishes a Design Formula  
14 for natural gas pipelines. The Design Formula is the same Barlow’s Formula used for calculating  
15 the internal hoop stress caused by the natural gas pressure discussed above, but it can also be  
16 used to determine maximum allowable design pressure. The Design Formula includes a Design  
17 Factor, represented by “F,” which varies based on the Class Location of the pipeline as governed  
18 by 49 CFR 192.111.<sup>4</sup> Class Locations are determined by a pipeline’s proximity to various  
19 dwellings, buildings, or places of public assembly.<sup>5</sup> The Design Formula calculates the Design

---

<sup>3</sup> See **Exhibit VGS-CC-4** (49 C.F.R. § 192.105)

<sup>4</sup> See **Exhibit VGS-CC-3** (49 C.F.R. § 192.111)

<sup>5</sup> See 49 C.F.R. § 192.5.

1 Pressure for a pipeline, which is the maximum allowable operating pressure on the pipeline when  
2 substantiated with the appropriate strength tests under the PHMSA regulations.

3 In the case of the ANGP, the Design Formula incorporates a “Design Factor” (or “F”) of  
4 0.5 because the ANGP is designed to meet Class 3 Location standards regardless of whether it is  
5 actually a Class 3 location as defined by the regulations. Using a Design Factor of 0.5 for Class 3  
6 and the same pipe specifications discussed above (nominal wall thickness, outside diameter, and  
7 SMYS), the Design Formula establishes a Design Pressure of 1590 for the ANGP:

$$8 \quad P = (2 St/D) \times F \times E \times T$$
$$9 \quad 1590 = (2 \times 65,000 \times 0.312''/12.75'') \times 0.5 \times 1.0 \times 1.0$$

10 At a Design Pressure of 1590, the maximum allowable internal hoop stress on the pipe is 32,500  
11 psi:

$$12 \quad S_H = PD/2t$$
$$13 \quad 32,500 = 1590 \times 12.75'' / 2 \times 0.312''$$

14 This means that under the Design Formula, the Design Pressure for the ANGP is 1590 and the  
15 corresponding internal hoop stress is 32,500 psi. In other words, a pipe of ANGP’s specifications  
16 operating at the Design Pressure of 1590 may produce an internal hoop stress equal to one half of  
17 the 65,000 SMYS (32,500 psi) if it is located in a Class 3 location, because the Design Factor  
18 used in the Design Formula is one half or 0.5.

19 Further, as noted above the Design Pressure for ANGP may be no more than 1590 for a  
20 Class 3 location. This value is greater than the VGS-established Maximum Operating Pressure  
21 (“MOP”) of 1440 for the ANGP which provides an added safety factor to the ANGP.



1 **Q7. How are the other stresses on the pipe calculated?**

2 **A7.** In addition to the internal hoop stress, additional stresses are assessed as part of the  
 3 surface loading evaluation. These additional stresses are noted in Answer 4 above and include  
 4 circumferential and longitudinal stresses associated with soil and surface load. To calculate  
 5 these additional stresses, several parameters are required as inputs to the surface load calculation  
 6 tools that we used, including the CEPA calculations (see Exhibit VGS-CC-2 at PDF page 32).  
 7 The following is a screen shot of our CEPA calculations, which show the HS20+15% surface  
 8 load, the weight of the soil, and the modulus of soil reaction highlighted in yellow. These inputs  
 9 represent soils that impose an overburden load acting downward on the pipeline as well as  
 10 representing a weak soil<sup>6</sup> that provides minimal support and resistance to the circumferential  
 11 stresses acting on the pipeline from the surface loading conditions.

| GENERAL INPUTS              |                              |                                    | VEHICLE INPUTS                 |                  | LOCATION OF MAXIMUM LOAD  |
|-----------------------------|------------------------------|------------------------------------|--------------------------------|------------------|---|
| D =                         | 12.75 inches                 | (Outside Diameter)                 | Axle or Track Separation 1 :   | 14 ft            | The maximum pressure exerted on the surface of the pipe due to vehicle point load occurs:<br><br><b>Under the middle tires.</b> |
| t =                         | 0.312 inches                 | (Wall Thickness)                   | Axle Separation 2 :            | 14 ft            |   |
| P <sub>internal</sub> =     | 1440 psig                    | (Maximum Operating Pressure)       | Axle Width :                   | 6 ft             |   |
| SMYS =                      | 65000 psi                    | (Specified Minimum Yield Strength) | Track Length :                 | N/A ft           |   |
| ΔT =                        | 0 °F                         | (Temperature Differential)         | Axle 1 or Track Vehicle Load : | 9200 lbs         |   |
| <b>ρ =</b>                  | <b>120 lb/ft<sup>3</sup></b> | <b>(Density)</b>                   | Contact Width 1 :              | 20 inches        |   |
| H =                         | 2 ft                         | (Depth of Cover)                   | Tire Pressure 1 :              | 100 psi          |   |
| θ =                         | 30 degrees                   | (Bedding Angle)                    | <b>Axle Load 2 :</b>           | <b>36800 lbs</b> |   |
| <b>E' =</b>                 | <b>100 psi</b>               | <b>(Modulus of Soil Reaction)</b>  | Contact Width 2 :              | 20 inches        |   |
| IF =                        | 1.50                         | (Impact Factor)                    | Tire Pressure 2 :              | 100 psi          |   |
| Soil Load Equation:         | Prism Load Equation          |                                    | Axle Load 3 :                  | 36800 lbs        |   |
|                             | φ =                          | N/A degrees                        | Contact Width 3 :              | 20 inches        |   |
| Equivalent Stress Equation: | Tresca Equation              |                                    | Tire Pressure 3 :              | 100 psi          |   |
|                             |                              |                                    | Measurement Point X-coord :    | N/A inches       |   |
|                             |                              |                                    | Measurement Point Y-coord :    | N/A inches       |   |

12 In order to assess these additional stresses acting on the pipeline, including the live load  
 13 of HS20+15% at the surface, we have to calculate and consider all of the stresses that are acting

---

<sup>6</sup> When we prepared our June 2021 memorandum, Mott MacDonald ran a sensitivity analysis to assess whether the ANGP would meet the HS20+15% loading standard with input values for soil strength that are lower than the 200 psi assumptions used in our 2016 and 2017 calculations. I consulted with our geotechnical team, which confirmed that a soil modulus of 100 psi is a conservative value, even for mucky, wet conditions in a wetland like the Clay Plains Swamp. We are confident that this sensitivity analysis is adequate for assessing conditions in the Clay Plains Swamp because we ran our calculations with even weaker soil conditions such as 50 psi and the ANGP still meets the HS20+15% loading standard under those more conservative conditions.

1 on the pipeline including those present under normal operating conditions. The evaluation to  
 2 consider all of these stresses together results in the dynamic state known as the “combined  
 3 biaxial stress state” or otherwise known as the “combined equivalent stress”.

4 There are two equations that can be used for combining the various stresses acting on the  
 5 pipeline to calculate the combined biaxial stress. The first is the Von Mises equation and the  
 6 second is called the Tresca Equation. For these calculations, the Tresca Equation represents the  
 7 more conservative approach because it always results in a higher combined biaxial stress than the  
 8 Von Mises equation. For this reason, Mott MacDonald used the Tresca equation in our  
 9 calculations using the CEPA method. The tool we used allows the user to select either Tresca or  
 10 Von Mises. With the Tresca equation, the “combined biaxial stress” at the maximum operating  
 11 pressure of 1440 (indicated as “@ MOP”) is 47,563.<sup>7</sup>

| CALCULATED STRESS DATA                              | Variable Description                             | Pipeline Regulatory Code | Pass / Fail |
|---|--|--------------------------|-------------|
| <b>Hoop Stress (<math>\sigma_H</math>):</b>         |  |                          |             |
| $\sigma_{H\_Internal\_MOP}$ = 29423 psi             | <----- Internal Pressure @ MOP                   |                          |             |
| $\sigma_{H\_Live\_Zero}$ = 22884 psi                | <----- Live Load @ Zero pressure                 |                          |             |
| $\sigma_{H\_Live\_MOP}$ = 11219 psi                 | <----- Live Load @ MOP                           |                          |             |
| $\sigma_{H\_Total\_Zero}$ = 24806 psi               | <----- Total Hoop Stress @ Zero pressure         |                          |             |
| $\sigma_{H\_Total\_MOP}$ = 41585 psi                | <----- Total Hoop Stress @ MOP                   |                          |             |
| $\sigma_{H\_SMYS\_Zero}$ = 38.2%                    | <----- Hoop Stress %SMYS @ Zero pressure         | ASME B31.8-2010          | PASS        |
| $\sigma_{H\_SMYS\_MOP}$ = 64.0%                     | <----- Hoop Stress %SMYS @ MOP                   | ASME B31.8-2010          | PASS        |
| <b>Longitudinal Stress (<math>\sigma_L</math>):</b> |  |                          |             |
| $\sigma_{L\_Live\_Zero}$ = 18303 psi                | <----- Live Load @ Zero pressure                 |                          |             |
| $\sigma_{L\_Live\_MOP}$ = 14522 psi                 | <----- Live Load @ MOP                           |                          |             |
| $\sigma_{L\_Total\_Zero}$ = 18879 psi               | <----- Total Longitudinal Stress @ Zero pressure |                          |             |
| $\sigma_{L\_Total\_MOP}$ = 23632 psi                | <----- Total Longitudinal Stress @ MOP           |                          |             |
| $\sigma_{L\_SMYS\_Zero}$ = 29.0%                    | <----- Longitudinal Stress %SMYS @ Zero pressure | ASME B31.8-2010          | PASS        |
| $\sigma_{L\_SMYS\_MOP}$ = 36.4%                     | <----- Longitudinal Stress %SMYS @ MOP           | ASME B31.8-2010          | PASS        |
| <b>Equivalent Stress (<math>\sigma_E</math>):</b>   |  |                          |             |
| $\sigma_{E\_Zero}$ = 43685 psi                      | <----- Equivalent Stress @ Zero pressure         |                          |             |
| $\sigma_{E\_MOP}$ = 47563 psi                       | <----- Equivalent Stress @ MOP                   |                          |             |
| $\sigma_{E\_SMYS\_Zero}$ = 67.2%                    | <----- Equivalent Stress %SMYS @ Zero pressure   | ASME B31.8-2010          | PASS        |
| $\sigma_{E\_SMYS\_MOP}$ = 73.2%                     | <----- Equivalent Stress %SMYS @ MOP             | ASME B31.8-2010          | PASS        |

<sup>7</sup> This is a screen shot from our CEPA calculations set forth at PDF page 32 of 33 on Exhibit VGS-CC-2.

1 **Q8. How do you determine if the overall stress on the pipeline is acceptable?**

2 **A8.** The calculated stress values for total circumferential, total longitudinal, and combined  
3 equivalent stress are then compared against the maximum permitted values as previously noted  
4 in our response to Question 4 above. The calculated values must be lower than the maximum  
5 permitted values in order to be acceptable and in accordance with ASME B31.8. The references  
6 from ASME B31.8 833 that govern the maximum permitted values are listed below:

7 **Total Longitudinal Stress (ASME B31.8 833.3):**

**833.3 Summation of Longitudinal Stress in  
Restrained Pipe**

(a) The net longitudinal stresses in restrained pipe are

$$S_L = S_p + S_T + S_X + S_B$$

Note that  $S_B$ ,  $S_L$ ,  $S_T$ , or  $S_X$  can have negative values.

(b) The maximum permitted value of  $|S_L|$  is  $0.9ST$ , where  $S$  is the specified minimum yield strength, psi (MPa), per para. 841.1.1(a), and  $T$  is the temperature derating factor per para. 841.1.8.

8 This section notes as follows: “(b) The maximum permitted value of  $S_L$  is  $0.9ST$ ,  
9 where  $S$  is the specified minimum yield strength, psi (MPa), per para. 841.1.1(a), and  $T$  is  
10 the temperature derating factor per para. 841.1.8.” Based on this provision, the sum of  
11 the longitudinal stresses is limited to 0.9 of SMYS or in other words 58,500 psi  
12 (65,000SMYS x 0.9 = 58,500).

13 **Total Circumferential Stress (ASME B31.8 833.9):**

(b) The maximum allowable sum of circumferential stress due to internal pressure and circumferential through-wall bending stress caused by surface vehicle loads or other local loads is  $0.9ST$ , where  $S$  is the specified minimum yield strength, psi (MPa), per para. 841.1.1(a), and  $T$  is the temperature derating factor per para. 841.1.8.

1           This section notes as follows: “(b) The maximum allowable sum of  
2           circumferential stress due to internal pressure and circumferential through-wall bending  
3           stress caused by surface vehicle loads or other loads is  $0.9ST$ , where  $S$  is the specified  
4           minimum yield strength, psi (MPa), per para. 841.1.1(a), and  $T$  is the temperature  
5           derating factor per para. 841.1.8.” Based on this provision, the sum of the  
6           circumferential stresses is limited to 0.9 of SMYS or in other words 58,500 psi  
7           ( $65,000SMYS \times 0.9 = 58,500$ ).

8           **Total Combined Biaxial Stress (ASME B31.8 833.4):**

**833.4 Combined Stress for Restrained Pipe**

(a) The combined biaxial stress state of the pipeline in the operating mode is evaluated using the calculation in either (1) or (2) below:

(1)  $|S_H - S_L|$  or

(2)  $[S_L^2 - S_L S_H + S_H^2]^{1/2}$

The maximum permitted value for the combined biaxial stress is  $kST$  where  $S$  is the specified minimum yield strength, psi (MPa), per para. 841.1.1(a),  $T$  is the temperature derating factor per para. 841.1.8, and  $k$  is defined in paras. 833.4 (b) and (c).

(b) For loads of long duration, the value of  $k$  shall not exceed 0.90.

(c) For occasional nonperiodic loads of short duration, the value of  $k$  shall not exceed 1.0.

9           Under this provision of ASME B31.8, the “maximum permitted value of the combined  
10          biaxial stress is  $kST$ .” This means that the total combined stress calculated using either the Von  
11          Mises (shown in 833.4(a)(2)) or Tresca (shown in 833.4(a)(1)) equations cannot exceed the value  
12          of  $k \times S \times T$ . The value of  $k$  is determined under (b) or (c) depending on the duration of the load.  
13          For loads of long duration, the value of  $k$  cannot exceed 0.9 ( $0.9 \times 65,000 \times 1.0 = 58,500$  psi). For  
14          loads of short duration, the value of  $k$  cannot exceed 1.0 ( $1.0 \times 65,000 \times 1.0 = 65,000$ ). In our  
15          calculations, we used the more conservative value for  $k$  of 0.9 even though the ANGP is not

1 subject to long duration loads in the Clay Plains Swamp. Based on these conservative  
2 assumptions, the total combined biaxial stress on the pipeline is limited to 58,500 psi.

3 To determine if the stress values are acceptable, the computed total longitudinal stress  
4 value must be less than 90% of SMYS, the total circumferential stress value must be less than  
5 90% of SMYS, and the total combined biaxial stress must be less than either 90% or 100% of  
6 SMYS depending on the load duration. For all of our calculations, Mott MacDonald used a 90%  
7 of SMYS value as the limiting and maximum value for assessing the resulting stresses from an  
8 HS-20+15% surface load.

9 **Q9. Does the ANGP meet the HS20+15% loading standard based on the requirements of**  
10 **ASME B31.8?**

11 **A9.** Yes. The total longitudinal, total circumferential, and total combined equivalent stress  
12 values on the ANGP from a HS20+15% surface load are well below the maximum permitted  
13 value of 58,500 psi. Our calculations and Mr. Liebert's CEPA calculation #4 are based on  
14 similar input values and both indicate that the ANGP passes the surface load standard. The  
15 results from our calculations are summarized below:

16 **Input Parameters:**

17 D = 12.75 inches

18 t = 0.312 inches

19  $P_{\text{internal}} = 1440$  psig

20 SMYS = 65,000 psi

21  $\Delta T = 0^{\circ}\text{F}$

1  $\rho = 120 \text{ lb/ft}^3$

2  $H = 2 \text{ ft}$

3  $\Theta = 30 \text{ degrees}$

4  $E' = 100 \text{ psi}$

5  $IF = 1.5$

6 Soil Load Equation = Prism Load Equation

7 Equivalent Stress Equation = Tresca Equation

8 **Results:**

9 Total Longitudinal Stress = 23,632 @MOP < 58,500psi (Per 833.3 – OKAY)

10 Total Circumferential Stress = 41,585 @MOP < 58,500psi (Per 833.9 – OKAY)

11 Total Combined Equivalent Stress = 47,563 @MOP < 58,500psi (Per 833.4 – OKAY)

12 Similarly, Mr. Liebert's calculations (CEPA #4) for similar input parameters result in acceptable  
13 calculated values as well as noted below:

14 Total Longitudinal Stress = 23,052 @MOP < 58,500psi (Per 833.3 – OKAY)

15 Total Circumferential Stress = 43,302 @MOP < 58,500psi (Per 833.9 – OKAY)

16 Total Combined Equivalent Stress = 43,302 @MOP < 58,500psi (Per 833.4 – OKAY)

17 Notably, this calculation is also based on several conservative assumptions. First, the ANGP  
18 generally operates at a natural gas pressure of less than 600 psi rather than 1440 psi, so the  
19 internal hoop stress is actually lower—even though VGS's pipe design would permit a Design  
20 Pressure under the terms of 49 C.F.R. § 192.105 of 1590 psi. Second, this calculation assumes  
21 only 2 feet of cover even though there is no location on the ANGP where the cover is only 2 feet.  
22 Given the conservative assumptions that we incorporated into our calculations, the ANGP clearly

1 meets an HS20+15% loading standard because all of the calculated stresses including total  
2 longitudinal, total circumferential, and total combined effective stress are below the maximum  
3 permitted value of 90% of SMYS (58,500 psi).

4 **Q10. Mr. Liebert testifies that ASME B31.8 requires the total allowable stress to be no**  
5 **more than 50% of SMYS because the Class 3 location Design Factor is 0.5. Is this correct?**

6 **A10.** No. Mr. Liebert is incorrect. His testimony confuses the Design Factor required in the  
7 Design Formula for determining the steel pipe design specifications with the requirements for  
8 calculating total longitudinal, total circumferential, and total combined biaxial stress on the  
9 pipeline from additional stresses on the pipeline, including weight of the soil above the pipe and  
10 surface or live load acting on the pipe as discussed above.

11 **Q11. What is the basis for Mr. Liebert’s confusion about how to determine total**  
12 **allowable stress?**

13 **A11.** In discovery, Mr. Liebert explained his conclusion by stating, “When calculating  
14 combined stresses for a crossing in a Location Class 3, a Factor of Safety of 0.50 is applied to the  
15 SMYS based on *ASME B31.8 §841* and *Tables 841.1.6-1 and 841.1.6-2*, when checking for a  
16 pass or fail condition.”<sup>8</sup> This statement identifies the source of Mr. Liebert’s confusion. The part  
17 of ASME B31.8 that Mr. Liebert cites to is Section 841. Section 841, however, sets forth the  
18 same Design Formula (Barlow’s Formula) established under 49 C.F.R. §192.105. This formula  
19 governs the Design Pressure and is used for establishing the steel pipe design specifications

---

<sup>8</sup> Intervenor Responses to VGS’s First Set of Interrogatories, Request to Produce, and Request to Admit (emphasis added).

1 including the nominal wall thickness, pipe diameter, and grade. This same formula also requires  
2 that the internal hoop stress produced by the Design Pressure be limited by a 0.5 factor for a  
3 Class 3 location. Tables 841.1.6-1 and 841.1.6 of the ASME B31.8 code simply state the Design  
4 Factors for various Class Locations to be used in the Design Formula. These provisions have  
5 nothing to do with calculating the total longitudinal, total circumferential, or combined biaxial  
6 stress on the pipeline from additional stresses on the pipeline, because that is governed by  
7 Section 833.

8 Mr. Liebert is referring to Section 841.6, which requires the use of a Design Factor based  
9 on Class Location in the Design Formula set forth in Section 841:

**841 STEEL PIPE**

**841.1 Steel Piping Systems Design Requirements**

**841.1.1 Steel Pipe Design Formula**

(a) The design pressure for steel gas piping systems or the nominal wall thickness for a given design pressure shall be determined by the following formula (for limitations, see para. 841.1.3):

*(U.S. Customary Units)*

$$P = \frac{2St}{D} FET$$

10 As you can see, this is the same Barlow's Formula set forth in 49 C.F.R. § 192.105. Accordingly,  
11 when Mr. Liebert retracted his September 10, 2021 testimony and replaced his citation to 49  
12 C.F.R. Part 192 with a citation to Section 841 of the ASME B31.8, it made no difference because  
13 Section 841 of ASME B31.8 is the same Design Formula.

14 As I testified above, the Design Formula is used to calculate the Design Pressure for the  
15 pipeline and to establish the pipe specifications including the nominal wall thickness, diameter  
16 and grade and is separate from assessing the resulting stress values from an applied surface load  
17 such as a HS-20+15%. The Design Formula requires the Design Pressure to be limited so that it



1 imposes an internal hoop stress of no more than 50% of SMYS for a Class 3 location. This  
2 “Design Factor” applies solely to the internal hoop stress, which is only one component of the  
3 stress evaluation that is performed as a result of an applied surface load. In the case of the  
4 ANGP, this limit is 32,500 psi from internal pressure and corresponds to a Design Pressure of  
5 1590 psi. In all of our calculations, the internal hoop stress is less than 32,500 psi, which  
6 complies with both 49 C.F.R. § 192.105 and Section 841 of ASME B31.8.

7 **Q12. Could the Design Factor cited in Section 841 of ASME B31.8 apply to both internal**  
8 **hoop stress and total allowable stress as suggested by Mr. Liebert?**

9 **A12.** No. Applying the Design Formula’s Design Factor of 50% as a limitation on total  
10 longitudinal, total circumferential, or combined biaxial stress, rather than 90% under Section 833  
11 as I explained above, does not make any sense for several reasons. First, it makes no practical  
12 sense because the Design Formula permits the Design Pressure in the pipeline to impose an  
13 internal hoop stress of up to 50% of SMYS from the natural gas pressure alone. If the same  
14 limitation of 50% of SMYS also applied to the resulting longitudinal, circumferential, or  
15 combined biaxial stress, the pipeline could not operate at Design Pressure and be buried without  
16 running afoul of Mr. Liebert’s limitation. This is because the backfill itself would impose an  
17 additional earth load stress on the pipe. So, if you were operating a buried pipeline at the allowed  
18 Design Pressure under the Design Formula, you are always going to have a total circumferential  
19 and combined stress of more than 50% of SMYS.

20 Second, Mr. Liebert is ignoring the requirements for assessing total longitudinal, total  
21 circumferential, and combined biaxial stress under ASME B31.8, which, as I explained above,

1 are set forth in Section 833 of ASME B31.8—not Section 841. When Mr. Liebert was questioned  
2 about Section 833 during discovery, he explained that the equations set forth in Section 833.4  
3 strictly address “the conditions of internal pressure only and not total loads or subsequent  
4 stresses on the pipe.”<sup>9</sup> This is entirely backwards because the Design Formula Mr. Liebert cites  
5 in Section 841 is limited to internal pressure, whereas Section 833.4 addresses “combined biaxial  
6 stress” from additional stresses. The additional stresses addressed in this section include vehicle  
7 loading as B31.8, Section 833.9 states, as I quoted above, “The maximum allowable sum of  
8 circumferential stress due to internal pressure and circumferential through-wall bending stress  
9 caused by **surface vehicle loads or other local loads** is  $0.9ST$ .” This means that the total  
10 circumferential stress caused by internal pressure, earth load, and vehicle live load must not  
11 exceed 90% of SMYS ( $0.9 \times S \times T$ ).<sup>10</sup> In the case of the ANGP, that limitation is 90% of 65,000,  
12 which is 58,500 as noted above.

13 Third, Mr. Liebert is clearly misunderstanding how the total stresses are being calculated  
14 by the GPTC, CEPA, and other surface loading calculation tools. When he was asked in  
15 discovery about the CEPA Surface Loading Calculator User Manual, see **Exhibit VGS-CC-7**,  
16 Mr. Liebert testified that he had never reviewed that manual before performing CEPA  
17 calculations using that tool.<sup>11</sup> This helps explain why Mr. Liebert disregarded ASME B31.8,  
18 Section 833 because the CEPA User Manual explains that the equations being used to calculate  
19 the combined biaxial stress state or combined equivalent stress are the same general Tresca and  
20 Von Mises equations set forth in Section 833.4 of ASME B31.8. Finally, Mr. Liebert’s claim that

---

<sup>9</sup> Deposition of Mr. Liebert, Volume 2 at 283.

<sup>10</sup> As noted above,  $T = 1$  for the ANGP because it is being operated at a temperature less than 250°F.

<sup>11</sup> Deposition of Mr. Liebert, Volume 2 at 266.

1 Section 833.4 of the ASME B31.8 is not relevant to the total allowable stress on a pipeline is  
2 inconsistent with the leading research on this issue.<sup>12</sup>

3 **Q13. In discovery, Mr. Liebert argued that ASME B31.8 Section 841 at paragraph**  
4 **841.1.11(e) supports his claim that the combined effective stress is limited to 50% SMYS. Is**  
5 **this correct?**

6 **A13.** No. Again, Mr. Liebert is mixing apples and oranges, so to speak. Section 841.1.11(e)  
7 addresses “Additional Underground Pipe Protection,” and states that, “The pipe design factor,  $F$ ,  
8 shall be in accordance with Table 841.1.6-2 for the crossing of roads and railroads.” For context,  
9 some Class Locations, such as Class 1 or 2 locations, have a basic Design Factor of .8, .72 or .6.  
10 This means that those pipelines can operate at a Design Pressure that corresponds to an internal  
11 hoop stress of 80%, 72% or 60% of SMYS. For crossing of roads and railroads, the Design  
12 Factor is reduced for Class 1 or 2 pipe but is 0.5 for Class 3 pipe under all locations. Section  
13 841.1.6, Table 841.1.6-2, and Section 841.1.11(e) are all referring to the Design Factor used in  
14 the Design Formula set forth at the beginning of Section 841. As explained above, this is the  
15 same Design Formula set forth in 49 C.F.R. § 192.105 and is not a limitation on the assessment  
16 of total longitudinal, total circumferential, or combined effective stress from additional stresses  
17 such as a HS20+15% vehicle load.

18 Additionally, Mr. Liebert’s discovery responses assert that the Design Factor cited in  
19 Section 841.1.11(e) is referring to the total allowable stress because it is referring to the GPTC,

---

<sup>12</sup> For example, See **Exhibit VGS-CC-5** (Development of a Pipeline Surface Loading Screening Process) at 9 (citing ASME B31.8 Section 833.4 and other related ASME provisions as a basis for establishing a screening tool with maximum combined effective stress of 90% of SMYS).

1 CEPA, and other surface loading calculators. Section 841.1.11(e) is not referring to surface  
2 loading calculation tools and does not apply the surface loading calculations at all. That  
3 paragraph refers to the guidance provided by API RP 1102 and a specific Appendix G-15 of the  
4 GPTC Guide Material. Those materials provide guidance about underground pipe protection.  
5 This section of the ASME B31.8 is simply stating that such guidance “may be considered.” For  
6 example, API 1102 provides guidance about pipe bedding and other underground protection.  
7 Nothing in Section 841.1.11(e) governs the appropriate assessment of total longitudinal, total  
8 circumferential, or combined effective stress.

9 **Q14. Do Mr. Liebert’s surface loading calculations demonstrate that the ANGP meets a**  
10 **HS20+15% loading standard?**

11 **A14.** Yes, they do. When Mr. Liebert submitted his September 10, 2021 testimony, he included  
12 an exhibit with calculations. After he changed that testimony on October 4, 2021, he also  
13 provided twelve additional calculations he had performed after he retracted his testimony about  
14 bedding angle, axle-weight, and soil inputs. Mr. Liebert’s new calculations appear to have been  
15 calculated on October 3, 2021 and were not filed with the Commission, but I am including them  
16 as **Exhibit VGS-CC-6**. The following table summarizes the results of Mr. Liebert’s calculations:

| Liebert Calculation Title | Input Parameters |                | Combined Equivalent Stress Value | Combined Equivalent Stress Check (< 90% SMYS / 58,500 psi) Pass (Y/N) |
|---------------------------|------------------|----------------|----------------------------------|---|
|                           | Depth of Cover   | Soil Embedment |                                  |   |
| CEPA 1                    | 1.5 ft           | 30 degrees     | 53,128                           | Yes   |
| CEPA 2                    | 1.5 ft           | 0 degrees      | 58,802                           | No  |
| CEPA 3                    | 2 ft             | 30 degrees     | 43,302                           | Yes   |
| CEPA 4                    | 2 ft             | 0 degrees      | 46,624                           | Yes   |
| GPTC 1                    | 1.5 ft           | 30 degrees     | 54,526                           | Yes   |
| GPTC 2                    | 1.5 ft           | 0 degrees      | 60,533                           | No  |
| GPTC 3                    | 2 ft             | 30 degrees     | 44,949                           | Yes   |
| GPTC 4                    | 2 ft             | 0 degrees      | 48,663                           | Yes   |
| GPTC 5                    | 1.7 ft           | 0 degrees      | 54,450                           | Yes   |
| WL 1                      | 4 ft             | NA             | 40,696                           | Yes   |
| WL 2                      | 3 ft             | NA             | 39,987                           | Yes   |
| WL 3                      | 2 ft             | NA             | 45,574                           | Yes   |

1           As noted in the table above, all of the calculations and computed combined biaxial stress  
 2 values are lower than the allowable 58,500 psi—even the ones Mr. Liebert calculated at less than  
 3 two feet of cover—except for two calculations that included only 1.5 feet of cover and a 0 degree  
 4 bedding angle. Neither of those inputs models conditions in the Clay Plains Swamp because the  
 5 depth of cover is greater than two feet and a zero-degree bedding angle is the equivalent of  
 6 placing the pipe on a ledge or an immovable subsurface like concrete. Accordingly, the  
 7 calculations that assume a normal bedding angle and a greater depth of cover are more  
 8 representative. In summary, Mr. Liebert’s calculations are consistent with Mott MacDonald’s

1 previous sensitivity analysis and calculations, which indicated that the ANGP pipeline is  
2 adequate to withstand surface loading of HS20+15% for depths of cover greater than two feet.<sup>13</sup>

3 **Q15. Have you reviewed Mr. Palmer’s September 10, 2012 testimony in this case?**

4 **A15.** Yes.

5 **Q16. Mr. Palmer refers to the testimony of Mr. Berger from August 14, 2013 and claims**  
6 **that the “Class 3 load-bearing standard of .5 is objective, verifiable and unambiguous.” Do**  
7 **you agree with Mr. Palmer’s testimony?**

8 **A16.** No. Mr. Palmer does not appear to understand what Mr. Berger is saying, and like Mr.  
9 Liebert, confuses the application of a Class 3 Design Factor of .5 with a “load-bearing standard.”  
10 I reviewed the Berger testimony cited by Mr. Palmer. In that testimony, Mr. Berger responds to  
11 the question, “What additional safety measures had VGS previously agreed to?” stating:

The entire pipeline will be built and operated to Class 3 requirements which include heavier wall pipe, operation of the pipeline at no greater than 50% Specified Minimum Yield Strength (SMYS), hydrostatic pressure testing to 1.5 times the MAOP (maximum allowable operating pressure), and valve spacing at Class 3 intervals. Additionally, they will install remote operating valves with SCADA control at gate stations, and they will have two types of over pressure protection at all gate stations feeding the new distribution systems.

---

<sup>13</sup> Mr. Liebert’s calculations included some using a Wheel Loading Analysis. That tool provides similar combined equivalent stress values at a depth of cover of 2 feet as compared to the CEPA and GPTC calculation tools (approximately 45,000 psi). This value is less than the allowable combined equivalent stress value of 58,500 psi allowed in 833.4. Mr. Liebert appears to argue those calculations demonstrate the ANGP does not meet the standard, but since the combined stress values are approximately the same, there is no basis for that conclusion. Moreover, Mr. Liebert argues that this tool establishes both “maximum allowable internal stress” and “maximum allowable combined stress” limits of 50% and 60% based on Class Location, but that is also not true. The 50% maximum for internal stress is consistent with the Design Formula, but the 60% value has no basis in any code or regulation. It appears to be a limitation specific to this calculation tool that is inconsistent with the total combined stress requirement of ASME B31.8, Section 833.4.

1 This paragraph is explaining the applicable “Class 3 requirements.” There is no Class 3 “load-  
2 bearing standard” as suggested by Mr. Palmer. As I have explained above, the Class 3  
3 requirements include the use of a Design Factor of 0.5 in the Design Formula set forth in 49  
4 C.F.R. 192.105, which governs the Design Pressure of a pipe with certain specifications. Mr.  
5 Berger is simply explaining that the Class 3 requirements instruct that the pipeline be operated at  
6 a Design Pressure that produces an internal hoop stress no greater than 50% of the SMYS. This  
7 is true on the ANGP, where the MOP of 1440 set by VGS is even lower than the allowed Design  
8 Pressure of 1590. There are no “Class 3 requirements” that establish a “load bearing standard,”  
9 as Mr. Palmer suggests. To the extent Mr. Palmer is referring to the maximum allowable biaxial  
10 stress from additional stress like surface loading, that standard is set forth in Section 833 of  
11 ASME B31.8 as I explained above.

12 **Q17. Does this conclude your testimony?**

13 **A17. Yes.**